


(WINDING SHEET DETAILS)

SHEET 1 OF 2
REV 0

JOB NO :	STD	QTY	1	REF : -	DT	025	ONAN	11	0.433	T1
KVA :	25	INPUT / OUTPUT	11000/433	PHASE	3	FREQ :	50Hz			
SECTION NO :- 1										
NO. OF PHASE.	3									
CONNECTION.	STAR									
PHASE VOLTS.	250.3									
WINDING TYPE.	SPIRAL									
WINDING SENSE.	NORMAL									
COIL NO.	1									
DISC. NO.	N.A									
BARE ALUMINIUM COND. SIZE. 8.3 x 3.25 ;										
COND. INS. & INSULATED SIZE. 0.3 ; DPC ; 8.6 X 3.55 ;										
COND. ARRANGEMENT. 1W x 1D ;										
INTER LAYER INSULATION. 2 X 5 MILS PPN BET. ALL LAYERS ;										
INTER LAYER DUCT. N.A ;										
IP. N.A ;										
CRT. N.A ;										
TRANSPOSITION DETAILS. N.A ;										
&										
(Kg.)										
LEAD	Lead length to be selected in such a way to direct termination to bushing									
NOTE	There should not be any joints in coils									
	Manufacture this coils with skilled labour who has previously done this type of short circuit coil									
1. ALL DIMENSIONS ARE IN m.m. UNLESS OTHERWISE SPECIFIED										
2. REFER SHEET NO. 2 FOR SECTION 2										
3. INSULATE ALL LEAD WITH 2 m.m RADIAL PI.										
<div style="display: flex; justify-content: space-between;"> <div>  <p>ANDREW YULE & CO. LTD ELECTRICAL DIVISION KOLKATA - 700083</p> </div> <div> <p>NAME</p> <p>DATE</p> </div> </div>										
<div style="display: flex; justify-content: space-between;"> <div> <p>TITLE : WINDING SHEET DETAILS</p> </div> <div> <p>PREPARED BY</p> <p>CHECKED BY</p> <p>APPROVED BY</p> </div> </div>										
SL NO.	REVISION	BY	DATE	FILE NO.	SCALE	DRAWING NO.				
THIS DRAWING IS STRICTLY CONFIDENTIAL. IT IS THE EXCLUSIVE PROPERTY OF ANDREW YULE & CO. LTD. & MUST NOT BE COPIED OR REPRODUCED IN PART OR WHOLE WITHOUT COMPANY'S WRITTEN PERMISSION.										