

ANDREW YULE & COMPANY LIMITED

Tea Division

Corrigendum

Scope of Work / Technical Specification

Ref.E-Tender No.: AYCL/TEA DIVISION/60/17-18/ET/236

Ref. Tender No.: TED/Capital/2017-18/25

1. Scope of Work

Supply as per specification, FOR garden including including Lowering & Commissioning at site.

2. Specification/Duty Condition/Scope of supply/requirement

Karbala Tea Estate

Pump type	Submersible, suitable for 200mm. diatubewell
Discharge	12000 GPH
Normal Head	75 Mtr.
Discharge Outlet (Internal)/Outlet	100 mm.
Motor Rating-HP	25
Method of Starting	Star Delta
Scope of supply	<ul style="list-style-type: none">• Complete submersible pump set . 1 No• Suitable control panel . 1 No.• Suitable cable alongwith cable clips . 180 ft x 2.

Requirement : 1 Set

New Dooars Tea Estate

Pump type	Submersible, suitable for 200 mm. dia pump
Discharge	12000 GPH
Normal Head	100 Mtr.
Discharge Outlet	100 mm.
Motor Rating-HP	25
Method of Starting	Star Delta
Scope of supply	<ul style="list-style-type: none">• Complete submersible pump set . 1 No.• Suitable cable alongwith cable clips . 130 mtr. x 2.• Suitable control panel . 1 No.

Requirement : 1 Set

Choonabhutti Tea Estate

Pump type	Submersible, suitable for 200 mm. diatubewell
Discharge	16000 GPH
Normal Head	72 Mtr.
Discharge Outlet	100 mm.
Motor Rating-HP	30
Method of Starting	Star Delta
Scope of supply	<ul style="list-style-type: none">• Complete submersible pump set . 1 No.• Suitable cable alongwith cable clips . 100 mtr. x 2.• Suitable control panel . 1 No.

Requirement : 1 Set

Last date for submission of desire documents as mentioned in Annexure . I of NIT No. AYCL/TEA DIVISION/60/17-18/ET/236 : 26.03.2018