

Event Catalogue						
Event Details						
Event no	Event start date & time	Event close date & time	Event View date & time	Prebid start date & time Prebid end date & time	Tender Type	Opening Type Act.Status
AYCL/Electrical Division CO/11/19-20/ET/42	10.05.2019 - 02:30 PM	01.06.2019 -12:00 PM	10.05.2019 - 02:35 PM	No Prebid Meet	Open	Itemwise Activated
Mode E-Tender Technical Cum Price Bid			TOE Start Time 2019-06-01 12:30:00.0		TOE End Time 2020-06-01 12:00:00.0	
Tender Committee Members						
Contact Person	Designation	Department	Email	Mobile No.	Telephone	
Tamilselvan	Engineer(Material)	Electrical Division CO	tamilselvan@andrewyule.com	9788520864	24960793	
Kingsly Reuben M	Assistant	Electrical Division CO	reuben@andrewyule.com	9884446378	24960793	
Lot Details						
Sno	Lot no	Lot name	Quantity	Uom	Description of Item	
1	1	20 MVA (66 -11 KV) Power Transformer along with Nitrogen fire protection system and Micro processor based numerical RTCC panel	1.0	NO	20 MVA (66- 11KV) Power Transformer along with Nitrogen Injection Fire Protection System and Micro processor based numerical RTCC panel as per our specification(FO:3687)	
1.1	TECHNO COMMERCIAL TERMS					
	1	REQUIREMENT -Tender offers are invited for supply of 20 MVA Power transformers as detailed below. 1. 20 MVA- (66/11KV) Power Transformer along with Nitrogen Injection Fire Protection System and Micro processor based numerical RTCC panel as per our specification (FO:3687) Qty-1 No Component : Agree Only				
	2	Validity period of the offer: Your offer should be valid for acceptance for a minimum period of 90 days from the date of tender opening. Component : Agree Only				
	3	Security Deposit. a) The EMD amount of the successful Bidder will be retained as security deposit towards the execution of the contract and the same will be released after completion of contract. b) If the bidder is exempted from paying EMD vide clause no 1 of Annexure III then on being awarded the contract , 1) The bidder should execute the bank guarantee /DD in favor of Andrew Yule & Co .Ltd for Rs.50,000/= . 2) For bidders already enlisted with AYCL- Chennai Operation, having outstanding amount more than the Security deposit amount then it will be adjusted towards Security Deposit. Component : Agree Only				
	4	ARBITRATION If any dispute arises between the company and the contractor, as to the terms and conditions of the agreement or method of compliance thereof, the procedure as laid down in Indian Arbitration & Consolidation Act 1996 will be adhered to. Component : Agree Only				
	5	RIGHTS OF THE COMPANY Bidders who have quote other payment terms & condition having financial implication will be loaded as per Andrew Yule norms. The company reserves the right to accept any tender irrespective of whether it is lowest or otherwise or to reject any or all tenders without assigning any reason thereof. Affordability of the rates is also a criterion in finalizing the offer. Component : Agree Only				
	6	FORCE MAJEURE In case of strike, accident, natural calamity, acts of god and other unforeseen contingencies causing stoppage of production at Andrew Yule Factory, Andrew Yule reserves the right to cancel and/or modify this contract without liability for compensation and/or claim of any description. Component : Agree Only				
	7	Legal condition: Any contract entered against this tender will be as per the following legal condition It is recorded that this purchase order / contract / agreement is executed and concluded by and between the parties hereto at premises No.5/346, Old Mahabalipuram Road, Perungudi, Chennai 600 096 and in the event any dispute arises out of this agreement between the parties only the appropriate Civil Court in the City of Kolkata shall have the exclusive jurisdiction to entertain, try and determine the said proceedings in exclusion of all other courts Component : Agree Only				
	8	Risk purchase clause: The company reserve the right to impose risk purchase clause as " For delay in execution / supply we shall have every right to do the same through some other agency/s which shall deemed fit and the additional cost of the same (Incidental/Consequential) shall be to your account which with respect to our intimation or observation whatsoever. Component : Agree Only				
	9	Liquidated damage : If the delivery is delayed beyond the date of scheduled date of dispatch in the purchase order, penalty will be levied @ 0.5% per week subject to a maximum of 10% Component : Agree Only				
	10	If there is any variation in the techno commercial terms as entered/agreed in the online bid and uploaded documents, then the details entered/agreed in the online bid will be the final. Component : Agree Only				
	11	Performance Bank Guarantee: As a guarantee towards performance of the transformer, the buyer will retain 10% of the invoice value for 18 months from the date of supply. Alternatively, the tenderer can execute a bank guarantee in the format of the buyer for 10% of invoice value (Including GST) which shall be valid throughout the guarantee period of 18 months from the date of supply with a claim period of another 3 months counted from the date of expiry of the guarantee period . Component : Agree Only				
	12	Guarantee: The transformer should be guaranteed for 18months from the date of receipt of transformer or 12months from the date of commissioning whichever is earlier. During the period if the product is found defective due to any of the above reason you shall undertake to repair the same at FREEOF COST. Component : Agree Only				
	13	Non-Disclosure Agreement: The bidder on being awarded the contract has to execute a Non-disclosure Agreement as per the buyers prescribed format. Component : Agree Only				
	14	Any reworks at site including leak and replacement/repair of failed components are in supplier scope. Component : Agree Only				
	15	Any major failure at site, which requires the transformer to be brought back to works for rectification, will be to supplier account. This will also include taking back the transformer and installing at site after rectification. Any defect during guarantee period due to inferior materials or faulty workmanship will be rectified or replaced by the supplier at free of cost. Component : Agree Only				
	16	The transformer after testing at supplier premises will be brought to AYCL Chennai works for carrying out routine test and any other tests as specified by the customer. The supplier has to consider the cost of transportation of the same including assembling and dismantling for the above tests. AYCL will provide crane facility. Any failure on the above tests due poor workmanship will be to supplier account. Component : Agree Only				
	17	The transformer will be dispatched with Andrew Yule name plate only. Component : Agree Only				

18	The rate quoted should be F.O.R. Chennai (Inclusive of Packing, Forwarding and Insurance) Component : Agree Only
19	The credit period will start from the date of receipt of material at Andrew Yule, Perungudi, Chennai. Component : Agree Only
20	Transformer should be manufactured as per our Production process as mentioned in Annexure VI Component : Agree Only
21	Transformer should be supplied as per our specification & Bill of materials as mentioned in Annexure VII Component : Agree Only
22	Transformer will be inspected & Tested as per our QAP as mentioned in Annexure VIII Component : Agree Only
23	PAYMENT TERMS : -Direct Credit In case it is agreed fill 24 with number of days of direct Component : Remarks Field
24	Please indicate the number of days of direct credit. a) 90 % within 90 days from the date of receipt of Transformer. b) 10% after guarantee period (Andrew Yule payment terms is minimum 90 days direct credit. If the offered payment terms is less than 90 days , bids will be opened at the sole discretion of Andrew Yule & price will be loaded as per Andrew Yule norms) Component : Remarks Field
25	PAYMENT TERMS : - Against L/c Bidders, who wish to quote with L/c, enter AGREE IN 25 and fill 27 with number of days of credit. Bidders, who have entered agreed in 23 and filled credit days in 24 should enter Disagree in 25 and fill 27 with 0 Component : Remarks Field
26	If L/c payment term is selected then the L/c opening charges will be to the bidders account. Component : Remarks Field
27	Please indicate the number of days of credit against L/c a) 90 % within 90 days from the date of receipt of Transformer. b) 10% after guarantee period (Andrew Yule payment term is minimum 90 days direct credit. For bidders offering L/c payment terms, bids will be opened at the sole discretion of Andrew Yule & price will be loaded as per Andrew Yule norms) Component : Remarks Field
28	If a bidder select AGREE in both 23 and 25, their payment terms will be considered as direct credit. Component : Agree Only
29	Qualifying Requirement: Should have experience in design, manufacture, testing and supply of Power transformers including after sales service activities. *Proof should be uploaded. **Those who are in the AYCL empaneled list of suppliers for transformers up to 16 MVA, 110/132 KV need not submit the above documents. Component : Remarks Field
30	The bidder shall have supplied 10 Nos. of oil filled transformers of assorted range& type up to 16 MVA, 110/132 KV class type within last 5 years (2013-14 to 2017-18) *Proof should be uploaded. **Those who are in the AYCL empaneled list of suppliers for transformers up to 16 MVA, 110/132 KV need not submit the above documents Component : Remarks Field
31	Should have minimum 2 nos of transformer of rating 8 MVA or above in Service for minimum 2 years. Bidders are requested to submit the Performance certificate for their highest rating of transformer. *Proof should be uploaded. **Those who are in the AYCL empaneled list of suppliers for transformers up to 16 MVA, 110/132 KV need not submit the above documents Component : Remarks Field
32	Should be ready to demonstrate the capability of design & manufacture strength by conducting type test and short circuit test as per the contractual requirement. **Those who are in the AYCL empaneled list of suppliers for transformers up to 16 MVA, 110/132 KV need not submit the above documents Component : Remarks Field
33	Shall have a minimum turnover of Rs. 15 crores in transformer Manufacturing in the last three financial years. (2015-16, 2016-17 & 2017-18)*Proof should be uploaded. **Those who are in the AYCL empaneled list of suppliers for transformers up to 16 MVA, 110/132 KV, Proof of turnover for year 2017-18 alone needs to be submitted Component : Remarks Field
34	The bidder should submit the documents as detailed below for Assessment of the supplier, a) Company profile b) Credentials along with details of execution of various rating of Power Transformer c) Copy of type and special test certificates d) List of technical competent person with specialization in related field e) Balance sheet for last three years (2015-16, 2016-17& 2017-18) *AYCL technical team will visit the bidder for assessment. **Those who are in the AYCL empaneled list of suppliers for transformers up to 16 MVA, 110/132 KV need not submit the above documents.(Sl.no 34 a to e). Proof of turnover for year 2017-18 alone needs to be submitted. Component : Remarks Field
35	EMD : Rs. 50,000/= * UP LOADED * Bidders may request for exemption from submitting EMD (Refer details given in General terms & conditions) Component : Remarks Field
36	Tender fee Rs: 200 /= should be paid by way of RGTS/ NEFT * UP LOADED * Bidders participating in the tender should upload the UTR details towards cost of tender document. Component : Remarks Field
37	Andrew Yule Scope of Supply 1. Name Plates Component : Agree Only
38	Delivery: within 3 months from the placement of our P/Order Component : Remarks Field
<u>Formula Details</u>	
<u>For Lot ::1</u> : 20 MVA (66 -11 KV) Power Transformer along with Nitrogen fire protection system and Micro processor based numerical RTCC panel	
a) BASIC PRICE PER NO (In Rs), b) CGST (In %) (If not applicable please enter Zero), c) SGST (In %) (If not applicable please enter Zero), d) IGST (In %) (If not applicable please enter Zero)	
Formula Entered by user ==> a	